

Certificate of Analysis

Product: Sodium Hypochlorite 12.5% Solution
Item Number: SHCN125
Grade: NSF60
Lot Number: 2023-3171
Manufacture Date: 03/31/2023
Expiration Date: 03/30/2025
Country of Origin: United States

Tested Property	Specification	Analysis
Sodium hypochlorite (NaOCl), %	12.5 - 13.20%	13.06
Available Chlorine, %	11.90 - 12.60%	12.44
Specific Gravity @ 25°C	1.18 - 1.24	1.20
Sodium Hydroxide, %	0.2 - 0.6%	0.4
Color/Clarity	Clear	Passes
Copper	Max 0.5 ppm	0.15
Iron	Max 1.0 ppm	0.12
Nickel	Max 0.5 ppm	0.09

[Sodium Hypochlorite 12.5% Solution](#)

Note: The information and recommendations of Lab Alley concerning this product are based upon laboratory tests and experience. To the best of our knowledge and belief these are true and accurate, however Lab Alley assumes no obligation or liability for the information in this document. Since conditions of actual use are beyond our control, any recommendations or suggestions regarding merchantability and fitness for particular purposes are made without warranty, expressed or implied.

This document was electronically issued and is therefore valid without a signature.

Phone: 512-668-9918, Fax: 512-886-4008,
 E-mail: Customerservice@laballey.com,
www.laballey.com,

12501 Pauls Valley Road, Suite A, Austin, Texas 78737.

© copyright: 2023 Lab Alley